



Product Service

# CERTIFICATE

No. Z2 119894 0001 Rev. 00

**Holder of Certificate:** **Zhejiang Chisage New Energy Technology Co., Ltd.**  
No. 177, West Jingu Middle Road, Panhuo Street  
Yinzhou District  
315000 Ningbo City, Zhejiang Province  
PEOPLE'S REPUBLIC OF CHINA

**Certification Mark:**



**Product:** **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**Mono-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 701262301701-00

**Valid until:** 2027-08-04

**Date,** 2023-02-15

( Zhulin Zhang )



# CERTIFICATE

No. Z2 119894 0001 Rev. 00

**Model(s):**

CExxx-33V-MH, xxx=640-675 in steps of 5  
 CExxx-30V-MH, xxx=575-615 in steps of 5  
 CExxx-27V-MH, xxx=520-560 in steps of 5  
 CExxx-25V-MH, xxx=475-510 in steps of 5  
 CExxx-20V-MH, xxx=375-410 in steps of 5  
 CExxx-36V-MH, xxx=520-555 in steps of 5  
 CExxx-30V-MH, xxx=430-465 in steps of 5  
 CExxx-27V-MH, xxx=390-415 in steps of 5  
 CExxx-36V-MH, xxx=410-460 in steps of 5  
 CExxx-30V-MH, xxx=335-385 in steps of 5  
 xxx is standing for rated output power at STC

**Parameters:**

|                         |  |
|-------------------------|--|
| Construction:           | Framed, with Junction box,<br>Cable and Connectors.  |
| Test Laboratory:        | Changzhou HuaYang Inspection and<br>Testing Technology Co., Ltd.<br>NO.8 Lanxiang Road, Wujin<br>Economic Development Zone,<br>Changzhou, Jiangsu, China |
| Safety Class:           | Class II   |
| Maximum System Voltage: | 1500 V DC  |
| Fire Safety Class:      | Class C according to UL790   |

**Tested  
according to:**

IEC 61215-1:2016  
 IEC 61215-1-1:2016  
 IEC 61215-2:2016  
 IEC 61730-1:2016  
 IEC 61730-2:2016  
 EN 61215-1:2016  
 EN 61215-1-1:2016  
 EN 61215-2:2017  
 EN IEC 61730-1:2018  
 EN IEC 61730-1:2018/AC:2018-06  
 EN IEC 61730-2:2018  
 EN IEC 61730-2:2018/AC:2018-06