CERTIFICATE OF CONFORMITY

Issued to:	Zhejiang Chisage New Energy Technology Co., Ltd. No.1828, Fuqing South Road, Panhuo Street, Yinzhou District, 315000 Ningbo City Zhejiang, China
For the product:	Hybrid inverter
Trade name:	CHISAGE ESS
Type/Model:	Ven-3G2-LE and Ven-3.6G2-LE
Ratings:	See Annex
Manufactured by:	Zhejiang Chisage New Energy Technology Co., Ltd. No.1828, Fuqing South Road, Panhuo Street, Yinzhou District, 315000 Ningbo City Zhejiang, China
Factory:	Ningbo Zhewei New Energy Co., Ltd.
Address:	2-2, No.181 Canghai Road, Ningbo High tech Zone.315000 Ningbo City Zhejiang, China
Requirements:	Engineering Recommendation G98 Issue 2: 2025 (G98/2)

Type of product certification scheme: Type 1a (Type approval)

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no. 6242013.56

The examination has been carried out on one single specimen of the product. The Attestation does not include an assessment of the manufacturer's production. Conformity of this production with the specimen tested by DEKRA is not the responsibility of DEKRA.

This Test Certificate expires at the latest on 15 June 2031 or expires upon withdrawal of one of the above mentioned standards.

Shanghai, 15 June 2026 Number: 6242013.01COC

DEKRA Testing and Certification (Shanghai) Ltd.

Kreny Lin
Certification Manager

IAS ACCREDITED Product Certification Agency

PCA-141

© Integral publication of this certificate and adjoining reports is allowed

DEKRA Testing and Certification (Shanghai) Ltd.
No.250, Jiangchangsan Road, Jing'an District, Shanghai, 200436 People's Republic of China
T +86 21 6056 7600 F +86 21 6056 7555 www.dekra-product-safety.com

Annex

Document no. : 6242013.01COC

Type	Ven-3G2-LE	Ven-3.6G2-LE
PV Input:		
Max. Voltage	500 Vdc	
MPPT Voltage Range	150 – 425 Vdc	
Max. Current	18 A / 18 A	
Isc PV	27 A / 27 A	
AC Input (from grid):		
Phase	L / N / PE	
Rated Voltage	230 Vac	
Frequency	50 / 60 Hz	
Rated Current	13 A	15,7 A
Rated Power	3000 W	3600 W
AC Output (to grid):		
Phase	L / N / PE	
Rated Voltage	230 Vac	
Frequency	50 / 60 Hz	
Rated Current	13 A	15,7 A
Rated Power	3000 W	3600 W
Power Factor	0,8 leading to 0,8 lagging	
AC Output (Stand alone):		
Phase	L / N / PE	
Rated Voltage	230 Vac	
Frequency	50 / 60 Hz	
Rated Current	13 A	15,7 A
Rated Power	3000 W	3600 W
Battery:		
Rated Voltage	48 Vdc	
Operating Voltage	40 – 60 Vdc	
Max. charge / discharge current	60 A	75 A

Hardware version: V00.00.001

Software version: V03001b/000106/21008

---End---